

875—62.4(88A) Walking surfaces, access and egress.

62.4(1) *General requirements.* Safe and adequate means of access to and egress from amusement rides, devices, concession booths, permanent structures and temporary structures shall be provided. The design, number, location and identification of exits shall be in accordance with the Standard for Tents, Grandstands and Air-Supported Structures Used for Places of Assembly, NFPA No. 102-1972, Section 7, Ways of Egress. All passageways are to be kept free from debris, obstructions, projections and other hazards. All surfaces shall be such as to prevent slipping and tripping, and floors shall be kept free of protruding nails, splinters, holes or loose boards. Where mechanical handling equipment is used, sufficient safe clearances shall be allowed for passageways.

62.4(2) *Stairways, landings and ramps.* Adequate stairways or ramps and the necessary landings and platforms shall be provided where people enter or leave a device, ride or structure that is above or below grade or floor level at entrance to or exit from such amusement. The design and construction of stairways, ramps and railings shall conform to 29 CFR, Chapter XVII, Part 1910 subpart D—Walking—Working surfaces as published at 39 Federal Register 23505 (June 27, 1974) except for the requirement of placement of stairway railings and guards. All stairs with more than one step shall have standard handrails or railings on both sides regardless of width, and when stairways are 88 inches or greater in width, a railing shall be placed approximately in the center. The construction of the standard railings and handrails shall be in accordance with the Federal Register cited in this subrule.